

energy right[®] Program
Heat Pump Plan
List of Accepted Outdoor Pads
December 2004

Carson Industries, Inc. 1925 A Street La Verne, CA 91750	Dura Grid
Century Steps, Inc. P.O. Drawer 228 Sulphur, LA 70664 318/527-5266	Century Lite Pads
Diversitech Corporation 1512 Green Street S.W. P.O. Box 1516 Conyers, GA 30207 404/922-5151	Cladlite Pads Ultralite Pads
GAIA Technologies, Inc. Condenser Pads 4710 Bellaire Blvd., Suite 301 Bellaire, Texas 77401	NuTek
Global - The Source 723 Coliseum Road San Antonio, Texas 78219	Global Perma Pad
MISCO Sales Associates, Inc. 2429 Woodbridge Dr. Marietta, GA 30066-2159	The Black Pad Mfgr: Poly Vulc USA, Inc. 1645 Haining Road Vicksburg, MS 39180
Tex-Flex, Inc. 3119A Eastman Road P.O. Box 3553 Longview, TX 75606 214/753-4251	Poly-Pads

General Notes On Approving Pads:

- Pads shall be 2-inch or greater in thickness
- Pads will keep the bottom of the coil at least 2" above ground (for snow build-up)
- Pads are structurally sound.
 - Concrete reinforcement
 - May require/ask for test data on other materials to determine if the strength of the materials will resist bending, sheer, cupping, and embrittlement.
- Pads will remain effective for the life of the unit +.
(may ask for accelerated aging test to support claims of effective life span)
- Is Pad Manufacturer willing to warrant the pad for the same life span as the heat pump?
- The above may be somewhat subjective evaluations. Tests and other criteria as determined by TVA review.